

# Dry Slip Test Certificate

Friday June 10<sup>th</sup>, 2016

Supplier: Terra Mater Hardwood Floors Pty Ltd (43 Nicholas Drive, Dandenong South, VIC 3175)

Sample Description: Lakewood

Date Tested: May 2016 (Tested through FORAY Laboratories – NATA Accreditation 1231)

Test Method: AS/NZS 4586-2004 Appendix B “Slip resistance classification of new pedestrian surface materials – Dry Floor Friction Test Method” using Slider 96

Test Data:

Sample Identification	Dry floor friction result <sup>1</sup>	Classification <sup>2</sup> (Standards Australia Handbook 197)
Lakewood	0.47	D1

<sup>1</sup> Five test average value

<sup>2</sup> The classifications indicate that the contribution of the floor surfaces to the risk of slipping when dry is low



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant



Tuan Duong  
B.Eng. (Chemical)  
Consultant

CV160428