

Emission Test Certificate

Monday, 05th December 2016

Supplier: Terra Mater Hardwood Floors Pty Ltd (43 Nicholas Drive, Dandenong South, VIC 3175)

Sample Description: Lamwood FM-1409

Date Tested: November 2016 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p>Green Building Council of Australia Green Star Interiors V1.1 - 12.1.2B Green Star Office Design v1.1 – 13.1.2B</p>	<p>Lamwood FM-1409</p>
<p>Total Volatile Organic Compound Emission Rate limit: <0.5 mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: <0.005 mg/m²/hr</p>
<p>4-phenylcyclohexene Emission Rate limit: <0.05 mg/m²/hr</p>	<p>4-phenylcyclohexene Emission Rate: <0.005 mg/m²/hr</p>
<p>Formaldehyde Emission Rate limit: <0.1 mg/m²/hr</p>	<p>Formaldehyde Emission Rate: 0.008 mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B Eng. (Chem.)
Consultant

CV161129a