

Emission Test Certificate

Tuesday, 16th October 2018

Supplier: Terra Mater Hardwood Floors Pty Ltd (23-27 Rodeo Drive, Dandenong South, VIC, 3175)

Sample Description: Linwood Misty Grey 3786 Flooring Board

Date Tested: September 2018 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116: 2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hrs):

<p>Green Building Council of Australia Green Star Interiors V1.1 - 12.1.2B Green Star Design & As Built V1.1 - 13.1.2B</p>	<p>Linwood Misty Grey 3786 Flooring Board</p>
<p>Total Volatile Organic Compound Emission Rate Limit: <0.500 mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.019 mg/m²/hr</p>
<p>Formaldehyde Emission Rate Limit: <0.1 mg/m²/hr</p>	<p>Formaldehyde Emission Rate: 0.037 mg/m²/hr</p>



Photo of tested specimen



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B.Eng. (Chemical)
Consultant

CV180899J