

Fire Test Certificate

Monday October 9th, 2017

Supplier: Terra Mater Hardwood Floors Pty Ltd (23-27 Rodeo Drive, Dandenong, VIC 3175)

Sample Description: 5 mm RESI Vinyl Plank

Date Tested: September 2017 (Tested through FORAY Laboratories – NATA Accreditation 1231)

Test Method: AS/ISO 9239.1-2003 Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source.

Test Data:

AS/ISO 9239.1-2003	5mm RESI Vinyl Plank
Critical Heat Flux/Critical Radiant Flux*	8.7 kW/m ²
Smoke Value*	217 %.min
Melting	Yes
Blistering	Yes

*Three test average value



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Dac Tuan Duong
B.Eng. (Chemical)
Consultant

CV170911