

Emission Test Certificate

Monday August 31st, 2020

Supplier: Terra Mater Hardwood Floors Pty Ltd (PO BOX 4540 Dandenong South VIC 3175)

Sample Description: SPC Vinyl Plank

Date Tested: August 2020 (Tested through FORAY Laboratories - NATA Accreditation 1231)

Test Method: ASTM D5116-17 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Materials/Products".

Emission Data (24 hrs exposure):

<p>Green Building Council of Australia Green Star Design & As Built v1.3 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.1.2B</p>	<p>SPC Vinyl Plank</p>
<p>Total Volatile Organic Compound Emission Rate limit: ≤0.5 mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.137 mg/m²/hr</p>
<p>Formaldehyde Emission Rate limit: ≤0.1 mg/m²/hr</p>	<p>Formaldehyde Emission Rate: <0.004 mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Consultant



Tuan Duong
B Eng. (Chem.)
Consultant

V2008018