

Wet Slip Test Certificate

Friday November 06th, 2020

Supplier: Terra Mater Hardwood Floors Pty Ltd (PO BOX 731, Heathmont, VIC, 3135, Australia)

Sample Description: SPC Vinyl Plank

Date Tested: November 2020 (Tested through FORAY Laboratories - NATA Accreditation 1231)

Test Method: AS/NZS 4586-2013 Appendix A "Slip resistance classification of new pedestrian surface materials – Wet Pendulum Test Method" using a Four S slider (Slider 96)

Test Data:


Sample Identification	Slip Resistance Value (SRV) ¹	Classification ² (Classification of Pedestrian Surface materials Accordance to The AS 4586 Wet Pendulum Test)
SPC Vinyl Plank	32	P2

¹ Five test average value

² The classifications indicate that the contribution of the floor surfaces to the risk of slipping when wet is high.



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Srikanth C. Srivatsa
PhD (Chemistry)
Consultant



Tuan Duong
PhD (Chemical Engineer)
Senior Consultant

V2010064